

**Addendum # 1**  
**FOR**  
**Woodland Drive 7<sup>th</sup> Street East**  
**City of Sturgis (Owner)**  
**1040 Harley-Davidson Way**  
**Sturgis, SD 57785**

**March 26, 2018**

The contractor is required to acknowledge receipt of this addenda on the proposal.

The Asphalt and Base quantities have been updated. The revised bid schedule should be used.

In addition, A concrete alternate for paving will be allowed. The concrete is required to be a minimum of 4000 psi concrete with fiber reinforcement. The concrete pavement would have to have concrete cylinder results to prove it will be drivable by July 13. A Bid Schedule for the concrete option will be posted as well.