

**City of Derby Water Pollution Control Authority
Monthly Report for the January 2026 Meeting**

❖ **Collection System (December 2025)**

- Responded to a total of 44 CBYD tickets with 1 emergency ticket.
- Responded to a total of 2 emergency after hours call outs.

❖ **Waste-Water Treatment Plant (December 2025)**

- Average Flow = 1.20 million gallons per day
- Total Flow = 37.18 million gallons, Max Daily Flow = 1.28 million gallons per day
- Average Total Nitrogen = 75.4 lbs./day, Permit Limit = 71 lbs./day (Annual Avg = 70.7/day)
- Average Effluent BOD = 8.3 mg/l (permit <30 mg/l)
- Average Suspended Solids = 4 mg/l (permit = 30 mg/l)
- Average Turbidity = 1.9

❖ **Maintenance**

- Raw sewage pump #2 taken offline for repairs. Now back in service
- North primary clarifier motor replaced. Now back in service
- Relay switch at Patty Ann pump station replaced. Now back in service
- New secondary control panel RTU installed and put in service

❖ **General**

- Average % solids with new press 25.36%
- Continuing to work with FEMA for disaster damage assistance for East Derby Siphon
- Continuing to work with DEEP, CTDOT, and Metro North for all proper permits for East Derby Siphon repair
- Plant pickup truck on order.

①

9.0

City of Derby
 Check/Voucher Register
 05 - Enterprise Funds (WPCA)
 10400 - Cash WPCA
 APS
 From 12/11/2025 Through 1/13/2026

Check Number	Document Date	Vendor Name	Check Amount	Transaction Description
12924	12/16/2025	AIRGAS USA *	66.15	WPCA Gases: Helium, Argon
12925	12/16/2025	BAHR SALES INC	640.00	4 Hrs Labor install cable and test equipment
12926	12/16/2025	CINTAS CORPORATION	44.72	WPC A Uniform Service
	12/16/2025	CINTAS CORPORATION	44.72	WPCA Uniform Service
12927	12/16/2025	CONSTELLATION NEWENERGY	4,808.66	1 Caroline St Electricity 10/17-11/1
	12/16/2025	CONSTELLATION NEWENERGY	101.83	24 Division St (WPCA) Electricity 10/16-11/17
	12/16/2025	CONSTELLATION NEWENERGY	125.52	25 Burtville Ave (WPCA) Electricity 10/16-11/17
12928	12/16/2025	FIRE EQUIPMENT HEADQUARTE	830.20	WPCA Fire Extinguisher Testing
12929	12/16/2025	FRONTIER	175.81	WPCA Plant Phones 11/25 - 12/24
12930	12/16/2025	GRAINGER *	92.70	WPCA Disposable Gloves
	12/16/2025	GRAINGER *	2,546.16	WPCA Rubber Boots
12931	12/16/2025	KINSLEY GROUP INC	1,270.75	145 Roosevelt DR (WPCA Pump St: Generator Maintenance
	12/16/2025	KINSLEY GROUP INC	546.25	Pump Station Generator Maintenanc 20 S. Division St (WPCA)
12932	12/16/2025	LOWES *	746.68	WPCA Plant Maintenance Supplies
12933	12/16/2025	PAYCOR INC	341.00	WPCA November Payroll Fees
12934	12/16/2025	PHOENIX ENVIRONMENTAL LAB	470.00	WPCA Lab Sample Anaysis
12935	12/16/2025	PMA COMPANIES INC *	4,458.40	WPCA Portion of December Statem
12936	12/16/2025	REGIONAL WATER AUTHORITY	777.39	Roosevelt Dr (WPCA) Water 10/08-11/10
12937	12/16/2025	STAMFORD WPCA REGIONAL	325.20	WPCA Lab Sample Anaysis
12938	12/16/2025	USA BLUE BOOK	647.78	WPCA Lab Supplies
12939	12/16/2025	WESTON/SAMPSON ENGINEERS	4,000.00	10/25-11/21 Proj. ENG24-0623
	12/16/2025	WESTON/SAMPSON ENGINEERS	1,600.00	8/23-9/26 Proj. ENG24-0623
12940	12/18/2025	25 SUMMIT AVE LLC	17.38	December 2025 SU/CF Refund 2025-07-0002931
12941	12/18/2025	MARCAZK HELEN (L U)	514.00	December 2025 SU/CF Refund 2025-17-0002052
12942	12/18/2025	MARTINEZ OROZCO SEBATAIN	43.19	December 2025 SU/CF Refund 2025-17-0005156
12943	1/5/2026	AARON ASSOCIATES OF CT	21,303.00	RTU-10 Secondary Control Panel & Blowers Upgrades
12944	1/5/2026	AMAZON CAPITAL SERVICES	103.15	WPCA Office Supplies
12945	1/5/2026	CINTAS CORPORATION	44.72	WPCA Uniform Service
	1/5/2026	CINTAS CORPORATION	44.72	WPCA Uniformn Service
12946	1/5/2026	COYNE CHEMICAL	10,409.32	WPCA Plant Chemicals
12947	1/5/2026	EDWARDS ANSWERING SEV INC	59.60	WPCA Answering Service
12948	1/5/2026	EVERSOURCE	1,139.42	1 Caroline St Gas 11/10-12/11
	1/5/2026	EVERSOURCE	233.44	140 Roosevelt Dr Gas 11/10-12/11
12949	1/5/2026	FRONTIER	506.94	WPCA Bundle 11/11-12/10
	1/5/2026	FRONTIER	506.94	WPCA Phones 12/11-1/10
	1/5/2026	FRONTIER	175.81	WPCA Plant Phones 12/25 - 1/24
12950	1/5/2026	JOHNSON CONTROLS BUILDING SOLUTIONS	586.96	Alarm System WPCA 10/01/25 - 9/30/2026
12951	1/5/2026	MIKE SADICK MACHINE	650.00	WCPA Plant Maintenance: Manufac Bronx
12952	1/5/2026	NATIONAL WATER MAIN CLEANING COMPANY	90,503.89	Sanitary Sewer Rehabilitation Phas

2

10 b

City of Derby
 Check/Voucher Register
 05 - Enterprise Funds (WPCA)
 10400 - Cash WPCA
 APV
 From 12/11/2025 Through 1/13/2026

<u>Check Number</u>	<u>Document Date</u>	<u>Vendor Name</u>	<u>Check Amount</u>	<u>Transaction Description</u>
12964	1/12/2026	PHOENIX ADVISORS LLC	(141.00)	WPCA Lab Sample Analysis
		Total 10400 - Cash WPCA	322,186.48	
		Total 05 - Enterprise Funds (WPCA)	322,186.48	
Report Total			322,186.48	

City of Derby
 Check/Voucher Register
 05 - Enterprise Funds (WPCA)
 10400 - Cash WPCA
 APV
 From 12/11/2025 Through 1/13/2026

<u>Check Number</u>	<u>Document Date</u>	<u>Vendor Name</u>	<u>Check Amount</u>	<u>Transaction Description</u>
12964	1/12/2026	PHOENIX ADVISORS LLC	(141.00)	WPCA Lab Sample Analysis
		Total 10400 - Cash WPCA	322,186.48	
		Total 05 - Enterprise Funds (WPCA)	322,186.48	
Report Total			322,186.48	